

<b>SOUTH COAST AIR QUALITY MANAGEMENT DISTRICT</b>  <b>ENGINEERING AND COMPLIANCE DIVISION</b>  <b>PERMIT APPLICATION EVALUATION AND CALCULATIONS</b>	PAGES 1	PAGE 1
	APPL NO 485297	DATE 4/27/10
	PROCESSED BY AS08	CHECKED BY

### **TITLE V PERMIT (REV 03) EVALUATION**

**Applicant's Name** Eastern Municipal Water District (EMWD)  
Temecula Valley Regional Water Reclamation Facility

**Mailing Address** 2270 Trumble Road  
P.O. Box 8300  
Perris, CA 92580-8300

**Equipment Location** 42565 Avenida Alvarado  
Temecula, CA 92590

#### **FACILITY ID 001703** **APPLICATION 485297- Title V Minor Permit Revision**

#### **Background**

Eastern Municipal Water District (EMWD) A/N 485927 was submitted for Title V permit revision (03). The Title V permit revision includes two permit applications. Two (2) applications (480859 and 480864) were submitted for the alteration/modification of Permits to Operate of stationary digester gas and/or natural gas fired spark ignition IC engines that drive blowers that provide air for the aeration tanks at the sewage treatment plant. The proposed equipment will be located at Eastern Municipal Water District Temecula Valley Regional Water Reclamation Facility (EMWD-TVRWRF) in Temecula.

Title V revision 03, to include the alteration/modification of two stationary digester gas and natural gas fired spark ignition IC engines that drive blowers that provide air for the aeration tanks at the sewage treatment plant is considered a minor permit revision, as there is not an increase in emissions and the modification to the two engines does not result in new or additional NSPS or NESHAP requirements.

Public notice is not required. For additional information please refer to the attached evaluation prepared for the EPA review.

Note: Title V Revision 02 (A/N 504673) was issued March 9, 2010.

#### **Rules Evaluation**

Compliance with applicable rules and regulations is expected.

#### **Conclusions and Recommendations**

A Permit to Construct is recommended for applications 480859 and 480864. A revised Title V permit is recommended after the completion of EPA review.